## 2017 CERTIFICATION

2018 JUN 25 AM 9: 49

Consumer Confidence Report (CCR)

Crustal Springs Water
Public Water System Name O150003
List PWS ID #s for all Community Water Systems included in this CCR
The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR. You must email, fax (but not preferred) or mail, a copy of the CCR and Certification to the MSDH. Please check all boxes that apply.
Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
☐ Advertisement in local paper (Attach copy of advertisement)
☐ On water bills (Attach copy of bill)
☐ Email message (Email the message to the address below)
□ Other
Date(s) customers were informed:/ /2018 / /2018 / /2018
CCR was distributed by U.S. Postal Service or other direct delivery. Must specify other direct delivery methods used_
Date Mailed/Distributed:/ /
CCR was distributed by Email (Email MSDH a copy)  Date Emailed: / / 2018
☐ As a URL(Provide Direct URL)
☐ As an attachment
☐ As text within the body of the email message
CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
Name of Newspaper: The Meteor
Date Published: Ob / 20/ 2018
CCR was posted in public places. (Attach list of locations)  Date Posted: / / 2018
CCR was posted on a publicly accessible internet site at the following address:
hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified bove and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true the Health, Bureau of Public Water Supply    Autor   Autor   Autor   Autor
Submission options (Select one method ONLY)

Mail: (U.S. Postal Service) MSDH, Bureau of Public Water Supply P.O. Box 1700 Jackson, MS 39215

Email: water.reports@msdh.ms.gov

Fax: (601) 576 - 7800
\*\*\*Not a preferred method due to poor clarity\*\*

CCR Deadline to MSDH & Customers by July 1, 2018!

## Crystal Springs Water Service PWS # 0150003 June 2018

2018 JUN 25 AM 9: 49

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Citronella & Miocene Aquifers.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Crystal Springs Water Service have received a lower to higher susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Alan Faler at 601-624-3403. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 6:00 PM at the City Hall.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2017. In cases where monitoring wasn't required in 2017, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and as production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that the tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level — the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) – The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Parts per million (ppm) or Milliframs per liter (mg/l) – one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter – one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST	RESULTS			7114-
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measurement	MCLG	MCL	Likely Source of Contamination

10. Barium	N	04/16/2014	0.0000					
To. Danum	N	04/16/2014	0.0203	0	ppm	2	2	Discharge of drilling wastes; discharge from
			1		-	1 1		mctal refineries;
		i i			1			erosion of natural
13. Chromium	N	04/16/2014	0.0016	0	<del> </del>			deposits
		*	0.0010	U	ppm	0.1	0.1	Po Tom proof
						1 1		and pulp mills; erosion
14. Copper	N	01/01/2014-	0.0	0	ppm	1.3	17 10	of natural deposits
<del></del>	1	12/31/2016		Ū	ppin	1.3	AL=1.3	Corrosion of household
	i.				1	1 1		plumbing systems;
			1		1	1 1		erosion of natural
			1		1	1		deposits; leaching from
16. Fluoride	N	2017	0.63	0.6-1.2	ppm	4	4	wood preservatives
	ł.	1 1		0.0 1.2	PPIII	1 1	4	Erosion of natural
	1	1				1 1		deposits; water additive
	1					1 1		which promotes strong
			1					teeth; discharge from fertilizer and aluminum
	l				1			factories
						1 1		Taciones
17. Lead	N	01/01/2014-	0.001	0	ppm	0	AL=0.015	Corrosion of household
		12/31/2016					12 0.010	plumbing systems,
		*			1			crosion of natural
10 37								deposits
19. Nitrate (as	N	01/24/2017	2.4	0	ppm	10	10	Runoff from fertilizer
Nitrogen)		1				1 1		use; leaching from
		1				1 1		septic tanks, sewage;
;		1	1		1			erosion of natural
20. Nitrite (as	N	01/01/00/0						deposits
Nitrogen)	N	01/24/2017	0	0	ppm	1	1	Runoff from fertilizer
Tita ogony		1 1	1			1 1		use; leaching from
		1 1	ŀ		1	1 1		septic tanks, sewage;
		1 .1	1		1	1 1		erosion of natural
Diai-C-4-	4. 0 1	D: : 0						deposits
Disinfectar	its & l	Disinfectio	n By-Pi	roducts				
There is convin	cing evid	lence that addit	ion of a dis	infectant is n	ecessary for	control of mi	icrobial contaminants.)	
OVER CITIES	N	2017	1.10	0.53-2.17	ppm	4.0	4.0	Water additive used to
asC12) (ppm)					1		4.0	
73. TTHM	N	07/02/2014	2.7	0	ppb	0	80	Control microbes
Total					1	١	80	By-product of drinking
rihalomethanes					1			water chlorination
					1			
Most recent		Ala annual		4-4				to the second se

<sup>\*</sup> Most recent sample. No sample required for 2017

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the State Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", our system is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which

average fluoride sample results were within the optimal range of 0.6-1.3 ppm was 10. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.3 ppm was 83%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottles water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water that the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Crystal Springs Water Service works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

**PROOF OF PUBLICATION** 



State of Mississ	i, Mississippi 39059 ippi, Copiah County
published at Crystal Springs, M notice a copy of which is h	e undersigned State, HENRY stal Springs Meteor, a newspaper dississippi, who on oath says the nereto attached, was printed tive times in said paper as follows:
JUNE 20,	2018 \$ 372.00
	\$
	\$
	\$
48 7 	\$
	\$
	Notary \$ 3,00
	Total Cost \$ 305,00
- Henry Ca	Publisher
Sworn to and subscribed before	e me this <u>2044</u> day of
gale Of	OUL resolutions